

(DRAFT) ORDINANCE NO. 474

2012 INTERNATIONAL CODE ADOPTIONS

AN ORDINANCE OF THE CITY OF SUN VALLEY, IDAHO, AMENDING SUBSECTIONS (B), (E), AND (H) OF SECTION 8-1-1, CODES ADOPTED, OF CHAPTER 1, TITLE 8, OF THE SUN VALLEY MUNICIPAL CODE, ADOPTING THE 2012 EDITION OF THE INTERNATIONAL RESIDENTIAL CODE (PARTS I, II, III, IV, V, VI, AND IX; INCLUDING APPENDICES A, B, D, E, F, G, H, J, K, AND M), 2012 EDITION OF THE INTERNATIONAL ENERGY CONSERVATION CODE, AND 2012 EDITION OF THE INTERNATIONAL FIRE CODE (INCLUDING APPENDICES B, C, D, AND I), ALL PUBLISHED BY THE INTERNATIONAL CODE COUNCIL, AND AMENDMENTS THERETO, AS THE OFFICIAL CODES FOR SAID CITY REGULATING ALL BUILDING, AS DEFINED IN THE SCOPE OF THE CODES; PROVIDING A SAVINGS AND SEVERABILITY CLAUSE; PROVIDING A CODIFICATION CLAUSE; PROVIDING A REPEALER CLAUSE; PROVIDING FOR PUBLICATION BY SUMMARY; AND, PROVIDING FOR AN EFFECTIVE DATE.

WHEREAS, every three years the State of Idaho adopts the most current version of Codes that address life, safety, health, fire protection, and standards for the built environment; and

WHEREAS, the Idaho Building Code Act requires local jurisdictions that enforce Codes to also adopt these Codes; and

WHEREAS, in February, 2014, following the State of Idaho's 2013 adoption action, the City of Sun Valley formally adopted the 2012 International Building Code and 2012 International Existing Building Code; and

WHEREAS, in 2014 the State of Idaho formally adopted the 2012 International Residential Code, 2012 International Energy Conservation Code, and 2012 International Fire Code and began enforcing each on January 1, 2015; and

WHEREAS, the City of Sun Valley currently enforces the 2009 International Residential Code, 2009 International Energy Conservation Code, and 2009 International Fire Code; and

WHEREAS, the City desires to adopt the 2012 International Residential Code, 2012 International Energy Conservation Code, and 2012 International Fire Code.

NOW, THEREFORE, BE IT ORDAINED by the Mayor and Council of the City of Sun Valley, Idaho that sections of City of Sun Valley Ordinance No. 439 are hereby repealed and that Title 8, Chapter 1, Section 8-1-1 of the City of Sun Valley Municipal Code, is hereby amended as follows:

SECTION 1. For Section 8-1-1, Codes Adopted, subsections (B), (E), and (H) of the Sun Valley Municipal Code are hereby amended as follows:

8-1-1: Codes Adopted: The following international codes are adopted by reference by the city of Sun Valley, Idaho:

- (B) The international residential code, ~~2009~~ 2012 edition, parts I through VI and part IX including appendices A, B, D, E, F, G, H, J, K, and M;
- (E) The international energy conservation code, ~~2009~~ 2012 edition;
- (H) The international fire code, ~~2009~~ 2012 edition, including appendices B, C, D, and I.

SECTION 2. Section 8-1-2-2 of the Sun Valley Municipal Code, is hereby amended as follows:

8-1-2-2: AMENDMENTS TO THE INTERNATIONAL RESIDENTIAL CODE:

Section R101.2 is amended as follows:

Delete exception No. 1 contained under IRC section R101.2 - Scope.

Section R101.2 is amended as follows:

Delete exception No. 2 contained under IRC section R101.2 - Scope, and replace with the following: Owner-occupied lodging houses with three (3) or fewer guestrooms shall be permitted to be constructed in accordance with the International Residential Code for One- and Two-family Dwellings. Such occupancies shall be required to install smoke alarms and carbon monoxide alarms in accordance with sections R314 and R315 respectively of the International Residential Code for One- and Two-family Dwellings.

Section R105.2 is amended as follows:

Delete item No. 2 contained under the "Building" subsection of IRC section R105.2 - Work exempt from permit, and replace with the following: Fences not over six (6) feet (one thousand, eight hundred twenty-nine (1,829) mm) high may be exempted from the requirement for a building permit in the absence of any other applicable land use regulations governing the installation, height, type or other aspect.

Section R105.2 is amended as follows:

Delete item No. 7 contained under the “Building” subsection of IRC section R105.2 - Work exempt from permit, and replace with the following: Prefabricated swimming pools that are not greater than four (4) feet (one thousand, two hundred nineteen (1219) mm) deep.

Section R105.2 is amended as follows:

Add the following item No. 11 at the end of the “Building” subsection of IRC section R105.2 - Work exempt from permit: Flag poles.

Section R109.1.3 is amended as follows:

Delete IRC section R109.1.3 and replace with the following: Floodplain inspections. For construction in areas prone to flooding as established by Table R301.2(1), upon placement of the lowest floor, including basement, the building official is authorized to require submission of documentation of the elevation of the lowest floor, including basement, required in section R322.

Section R302.1 is amended as follows:

IRC Table R302.1 Exterior Walls -- delete the figures contained in the last column of the table under the heading Minimum Fire Separation Distance for the “Walls” and “Projections” elements, and replace with the following:

Minimum Fire Separation Distance
Walls (fire-resistance rated): < Three (3) Feet
Walls (not fire-resistance rated): ≥ Three (3) Feet
Projections (fire-resistance rated): < Three (3) Feet
Projections (not fire-resistance rated): ≥ Three (3) Feet

Section R302.2 is amended as follows:

Delete the exception contained under IRC section R302.2 -- Townhouses, and replace with the following: Exception: A common one-hour or two-hour fire resistance rated wall assembly tested in accordance with ASTM E 119 or UL 263 is permitted for townhouses if such walls do not contain plumbing or mechanical equipment, ducts or vents in the cavity of the common wall. The wall shall be rated for fire exposure from both sides and shall extend to and be tight against the exterior walls and the underside of the roof sheathing. Penetrations of electrical outlet boxes shall be in accordance with section R302.4.

Section R303.4 is amended as follows:

Delete IRC section R303.4.

Section R313.1 is amended as follows:

Delete the exception contained under IRC section R313.1 -- Townhouse automatic fire sprinkler systems, and replace with the following: Exception: Automatic residential fire sprinkler systems shall not be required in townhouses where a two-hour fire-resistance rated wall is installed

between dwelling units or when additions or alterations are made to existing townhouses that do not have an automatic residential fire sprinkler system installed.

Section R313.2 is amended as follows:

Delete IRC section R313.2.

Section R315.3 is amended as follows:

Add the following to IRC section R315.3 - Where required in existing dwellings: Exceptions: 1. Work involving the exterior surfaces of dwellings, such as, but not limited to, replacement of roofing or siding, or the addition or replacement of windows or doors, or the addition of a porch or deck or electrical permits, are exempt from the requirements of this section; and 2. Installation, alteration or repairs of noncombustion plumbing or mechanical systems are exempt from the requirements of this section.

Section R322.1.10 is amended as follows:

Delete IRC section R322.1.10.

Section R322.2.2 subparagraph 2.2 is amended as follows:

Delete IRC section R322.2.2 subparagraph 2.2, and replace with the following: The total net area of all openings shall be at least one (1) square inch (645 mm²) for each square foot (0.093 m²) of enclosed area, or the opening shall be designed and the construction documents shall include a statement that the design and installation of the openings will provide for equalization of hydrostatic flood forces on exterior walls by allowing the automatic entry and exit of floodwaters.

Section R501.3 is amended as follows:

Delete IRC section R501.3 and its exceptions.

Section R602.10 is amended as follows:

Delete IRC section R602.10 and replace with the following: Wall bracing. Buildings shall be braced in accordance with this section or, when applicable section R602.12, or the most current edition of APA System Report SR-102 as an alternate method. Where a building, or portion thereof, does not comply with one (1) or more of the bracing requirements in this section, those portions shall be designated and constructed in accordance with section R301.1.

Section N1102.4.3 is amended as follows:

Delete section N1102.4.3 and replace with the following: Fireplaces. New wood-burning fireplaces shall have tight-fitting flue dampers and outdoor combustion air.

Part 4, Chapter 11, is amended as follows:

Chapter 11 [RE] Energy Efficiency - The following sections and tables of chapter 11 shall be amended in accordance with the requirements contained below in Subsection 004.04 of these

rules which correspond to the appropriate section:

- i. Table N1102.1.1 (Table R402.1.1) - Insulation and Fenestration Requirements by Component;
- ii. Table N1102.1.3 (Table R402.1.3 - Equivalent U-Factors);
- iii. Table N1102.2.6 (Table R402.2.6) - Steel-Frame Ceiling, Wall and Floor Insulation (R-Value);
- iv. Section N1102.4.1 (R402.4.1) Building Thermal Envelope;
- v. Section N1102.4.1.1 (R402.4.1.1) - Insulation;
- vi. Table N1102.4.1.1 (Table R402.4.1.1) - Air Barrier and Insulation Installation;
- vii. Section N1102.4.1.2 (R402.4.1.2) Testing Option;
- viii. Add Section N1102.4.1.3 (R402.4.1.3) - Visual Inspection Option;
- ix. Add Section N1102.6 (R402.6) - Residential Log Home Thermal Envelope;
- x. Add Table N1102.6 (Table R402.6) - Log Home Prescriptive Thermal Envelope Requirements by Component; and
- xi. Section N1104.1 (R404.1) - Lighting Equipment.

SECTION 3. Section 8-1-2-5 of the Sun Valley Municipal Code, is hereby amended as follows:

8-1-2-5: AMENDMENTS TO THE INTERNATIONAL ENERGY CONSERVATION CODE:

Table R402.1.1 (Table N1102.1.1) is amended as follows:

Delete the values contained in Table R402.1.1 (Table N1102.1.1) for climate zone “5 and Marine 4” and climate zone “6” and replace with the following:

**Table R402.1.1
INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT**

Climate Zone	Fenestration U-Factor	Skylight U-factor	Glazed Fenestration SHGC	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement Wall R-Value	Slab R-Value	Crawlspace Wall R-Value
5 and Marine 4	0.35	0.60	NR	38	20 or 13+5h	13/17	30g	10/13	10, 2 ft	10/13
6	0.35	0.60	NR	49	20 or 13+5h	15/19	30g	15/19	10, 4 ft	10/13

Table 402.1.1 is amended as follows:

Add the following footnote to the title of Table 402.1.1 - Insulation and Fenestration Requirements by Component: k. For residential log home building thermal envelope construction

requirements see section 402.6.

Table R402.1.3 (Table N1102.1.3) is amended as follows:

Delete the values contained in Table R402.1.3 (Table N1102.1.3) for climate zone “5 and Marine 4” and climate zone “6” and replace with the following:

**Table R402.1.3
EQUIVALENT U-FACTORS**

Climate Zone	Fenestration U- Factor	Skylight U-factor	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement Wall R-Value	Crawlspace Wall R-Value
5 and Marine 4	0.35	0.60	0.030	0.057	0.082	0.033	0.059	0.065
6	0.35	0.60	0.026	0.057	0.060	0.033	0.050	0.065

Table R402.2.6 (Table N1102.2.6) is amended as follows:

Delete Table R402.2.6 (Table N1102.2.6) and replace with the following:

**TABLE R402.2.6
STEEL-FRAME CEILING, WALL AND FLOOR INSULATION
(R-VALUE)**

WOOD FRAME R-VALUE REQUIREMENT	COLD-FORMED STEEL EQUIVALENT R-VALUE^a
Steel Truss Ceilings	
R-30	R-38 or R-30 + 3 or R-26 + 5
R-38	R-49 or R-38 +3
R-49	R-38 + 5
Steel Joist Ceilings	
R-30	R-38 in 2 x 4 or 2 x 6 or 2 x 8 R-49 in any framing
R-38	R-49 in 2 x 4 or 2 x 6 or 2 x 8 or 2 x 10
Steel-Framed Wall	
R-13	R-13 + 5 or R-15 + 4 or R-21 + 3 or R-0 + 10
R-19	R-13 + 9 or R-19 + 8 or R-25 + 7

R-21	R-13 + 10 or R-19 + 9 or R-25 + 8
Steel Joist Floor	
R-13	R-19 in 2 x 6 R-19 + 6 in 2 x 8 or 2 x 10
R-19	R-19 + 6 in 2 x 6 R-19 + 12 in 2 x 8 or 2 x 10
<p>a. Cavity insulation R-value is listed first, followed by continuous insulation R-value. b. Insulation exceeding the height of the framing shall cover the framing.</p>	

Section 402.4.1 (N1102.4.1) is amended as follows:

Delete Section 402.4.1 (N1102.4.1) and replace with the following: Building thermal envelope. The building thermal envelope shall comply with sections R402.1.1 and either section R402.4.1.2 or R402.4.1.3. The sealing methods between dissimilar materials shall allow for differential expansion and contraction.

Section 402.4.1.1 (N1102.4.1.1) is amended as follows:

Delete Section 402.4.1.1 (N1102.4.1.1) and replace with the following: Installation. The components of the building thermal envelope as listed in Table R402.4.1.1 shall be installed in accordance with the manufacturer's instructions and the criteria listed in Table R402.4.1.1, as applicable to the method of construction.

Table R402.4.1.1 (Table N1102.4.1.1) is amended as follows:

Delete the criteria requirement for the "Fireplace" component of Table R402.4.1.1 (Table N1102.4.1.1) - Air Barrier and Insulation Installation, and replace with the following: An air barrier shall be installed on fireplace walls.

Section 402.4.1.2 (N1102.4.1.2) is amended as follows:

Delete section 402.4.1.2 (N1102.4.1.2) and replace with the following: Testing option, Building envelope tightness and insulation installation shall be considered acceptable when tested air leakage is less than seven (7) air changes per hour (ACH) when tested with a blower door at a pressure of 33.5 psf (50 Pa). Testing shall occur after rough in and after installation of penetrations of the building envelope, including penetrations for utilities, plumbing, electrical, ventilation and combustion appliances. During testing:

- i. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed;
- ii. Dampers shall be closed, but not sealed, including exhaust, intake, makeup air, backdraft and flue dampers;
- iii. Interior doors shall be open;

- iv. Exterior openings for continuous ventilation systems and heat recovery ventilators shall be closed and sealed;
- v. Heating and cooling system(s) shall be turned off;
- vi. HVAC ducts shall not be sealed; and
- vii. Supply and return registers shall not be sealed.

Section 402.4.1 (N1102.4.1) is amended as follows:

Add the following as section 402.4.1.3 (N1102.4.1.3): Visual inspection option, Building envelope tightness and insulation installation shall be considered acceptable when the items listed in Table 402.4.1.1, applicable to the method of construction, are field verified. Where required by code official an approved party independent from the installer of the insulation shall inspect the air barrier and insulation.

Section 402.4.3 is amended as follows:

Delete section 402.4.3 and replace with the following: Fireplaces. New wood-burning fireplaces shall have tight-fitting flue dampers and outdoor combustion air.

Section R402 (N1102) is amended as follows:

Add the following section: R402.6 (N1102.6) Residential Log Home Thermal Envelope. Residential log home construction shall comply with sections 401 (General), 402.4 (Air Leakage), 402.5 (Maximum Fenestration U-Factor and SHGC), 403.1 (Controls), 403.2.2 (Sealing), 403.2.3 (Building Cavities), sections 403.3 through 403.9 (referred to as the mandatory provisions), Section 404 (Electrical Power and Lighting Systems), and either Subparagraph 004.04.b.i., ii., or iii. as follows:

- i. Sections 402.2 through 402.3, 403.2.1, 404.1 and Table 402.6;
- ii. Section 405 Simulated Performance Alternative (Performance); or
- iii. REScheck (U.S. Department of Energy Building Codes Program).

Section R402.6 (Table N1102.6) is amended as follows:

Add Table R402.6 (Table N1102.6) Log Home Prescriptive Thermal Envelope Requirements By Component to be used only in accordance with Subparagraph 004.04.b.i. above to appear as follows:

**TABLE R402.6
LOG HOME PRESCRIPTIVE THERMAL ENVELOPE REQUIREMENTS BY COMPONENT**

For SI: 1 foot = 304.8 mm.

Climate Zone	Fenestration U-Factor ^a	Skylight U-factor	Glazed Fenestration SHGC	Ceiling R-Value	Min. Average LOG Size in Inches	Floor R-Value	Basement Wall R-Value ^d	Slab R-Value & Depth ^b	Crawlspace Wall R-Value ^d
5,6- High efficiency equipment	0.32	0.60	NR	49	5	30	15/19	10, 4 ft.	10/13

path ^c									
5	0.32	0.60	NR	49	8	30	10/13	10, 2 ft.	10/13
6	0.30	0.60	NR	49	8	30	15/19	10, 4 ft.	10/13
<p>a. The fenestration U-factor column excludes skylights. The SHGC column applies to all glazed fenestration.</p> <p>b. R-5 shall be added to the required slab edge R-values for heated slabs.</p> <p>c. 90% AFUE natural gas or propane, 84% AFUE oil, or 15 SEER heat pump heating equipment (zonal electric resistance heating equipment such as electric base board electric resistance heating equipment as the sole source for heating is considered compliant with the high efficiency equipment path).</p> <p>d. "15/19" means R-15 continuous insulated sheathing on the interior or exterior of the home or R-19 cavity insulation at the interior of the basement wall. "15/19" shall be permitted to be met with R-13 cavity insulation on the interior of the basement wall plus R-5 continuous insulated sheathing on the interior or exterior of the home. "10/13" means R-10 continuous insulated sheathing on the interior or exterior of the home or R-13 cavity insulation at the interior of the basement wall.</p>									

Section R404.1 (N1104.1) is amended as follows:

Delete section R404.1 (N1104.1) and replace with the following: Lighting equipment (Mandatory). A minimum of fifty percent (50%) of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps or a minimum of fifty percent (50%) of the permanently installed lighting fixtures shall contain only high efficacy lamps.

SECTION 4. Section 8-1-2-8 of the Sun Valley Municipal Code, is hereby amended as follows:

8-1-2-8: AMENDMENTS TO THE INTERNATIONAL FIRE CODE:

Section 307.4.3 is amended to require the following:

Non-temporary fire pits shall be constructed to burn non-solid fuel only. No solid fuel burning is permitted in permanent outdoor fireplaces.

Section 307.4.3 is amended to exclude the following:

Amend Section 307.4.3 to eliminate the exception for portable outdoor fireplaces used at one- and two-family dwellings to be less than 15 feet (3048 mm) of a structure or combustible materials.

Section 503.2.7 is amended to read as follows:

Grade. The grade of the fire apparatus access road, including driveways, shall be within the limits established by the fire chief based on the fire department's apparatus. The grade of the fire apparatus road, including driveways, shall be no more than 7%, unless otherwise approved by the fire chief up to a maximum of 10%.

Section 505.1 is amended to require as follows:

Numbers shall be a minimum of 6 inches (152.4 mm) high with a minimum stroke width of 0.75 inch (19.05 mm).

Section 507.5.5 is amended to read as follows:

Clear space around hydrants. A 5-foot (1,524 mm) clear space shall be maintained around the circumference of fire hydrants, except as otherwise required or *approved*.

Section 603.8.2 is amended to read as follows:

Spark arrestor. All chimneys, fireplaces, and incinerators (or similar) that are capable of burning solid fuel shall be equipped with an effective means for arresting sparks. Required spark arrestors shall be installed per IRC 1003.9.1 and IBC 2113.9.1 as inspected and enforced by the city.

Appendix B104.1 is amended to read as follows:

General. The fire-flow calculation area shall be the total floor area of all floor levels within the exterior surface of the walls, and under the horizontal projections of the roof of a building that are greater than 4 feet.

SECTION 5. SAVINGS AND SEVERABILITY CLAUSE. It is hereby declared to be the legislative intent that the provisions and parts of this Ordinance shall be severable. If any paragraph, part, section, subsection, sentence clause or phrase of this Ordinance is for any reason held to be invalid for any reason by a Court of competent jurisdiction, such decision shall not affect the validity of the remaining portions of this Ordinance.

SECTION 6. CODIFICATION CLAUSE. The City Clerk is instructed to immediately forward this ordinance to the codifier of the official municipal code for proper revision of the code.

SECTION 7. REPEALER CLAUSE. All City of Sun Valley Ordinances or resolutions or parts thereof which are in conflict herewith are hereby repealed.

SECTION 8. PUBLICATION. This Ordinance, or a summary thereof in compliance with Section 50-901A, Idaho Code, substantially in the form annexed hereto as Exhibit "A", shall be published once in the official newspaper of the City, and shall take effect immediately upon its passage, approval, and publication.

SECTION 9. EFFECTIVE DATE. This Ordinance shall be in full force and effect from and after its approval, passage, and publication as provided by law.

PASSED BY THE CITY COUNCIL OF THE CITY OF SUN VALLEY, IDAHO, AND APPROVED BY THE MAYOR OF THE CITY OF SUN VALLEY on this 5th day of February, 2015.

EFFECTIVE DATE OF PUBLICATION: February 11, 2015.

APPROVED:

Dewayne Briscoe, Mayor
City of Sun Valley

ATTEST:

Alissa Weber, City Clerk
City of Sun Valley

EXHIBIT "A"

**PUBLICATION OF SUMMARY OF ORDINANCE NO. 474
CITY OF SUN VALLEY, IDAHO**

2012 INTERNATIONAL CODE ADOPTIONS

AN ORDINANCE OF THE CITY OF SUN VALLEY, IDAHO, AMENDING SUBSECTIONS (B), (E), AND (H) OF SECTION 8-1-1, CODES ADOPTED, OF CHAPTER 1, TITLE 8, OF THE SUN VALLEY MUNICIPAL CODE, ADOPTING THE 2012 EDITION OF THE INTERNATIONAL RESIDENTIAL CODE (PARTS I, II, III, IV, V, VI, AND IX; INCLUDING APPENDICES A, B, D, E, F, G, H, J, K, AND M), 2012 EDITION OF THE INTERNATIONAL ENERGY CONSERVATION CODE, AND 2012 EDITION OF THE INTERNATIONAL FIRE CODE (INCLUDING APPENDICES B, C, D, AND I), ALL PUBLISHED BY THE INTERNATIONAL CODE COUNCIL, AND AMENDMENTS THERETO, AS THE OFFICIAL CODES FOR SAID CITY REGULATING ALL BUILDING, AS DEFINED IN THE SCOPE OF THE CODES; PROVIDING A SAVINGS AND SEVERABILITY CLAUSE; PROVIDING A CODIFICATION CLAUSE; PROVIDING A REPEALER CLAUSE; PROVIDING FOR PUBLICATION BY SUMMARY; AND, PROVIDING FOR AN EFFECTIVE DATE.

A summary of the principal provisions of Ordinance No. 474 of the City of Sun Valley, Blaine County, Idaho, adopted on February 5th, 2015, is as follows:

SECTION 1. Repeals sections of Ordinance Number 439 and amends Section 1 of Chapter 1 of Title 8, Codes Adopted, of the Sun Valley Municipal Code, and provides for adoption of the 2012 edition of the International Residential Code (Parts I, II, III, IV, V, VI, and IX; including Appendices A, B, D, E, F, G, H, J, K, and M), 2012 edition of the International Energy Conservation Code, and 2012 edition of the International Fire Code (including Appendices B, C, D, and I).

SECTION 2. Provides for amendments to the International Residential Code.

SECTION 3. Provides for amendments to the International Energy Conservation Code.

SECTION 4. Provides for amendments to the International Fire Code.

SECTION 5. Provides a Savings and Severability Clause.

SECTION 6. Provides a Codification Clause.

SECTION 7. Provides a Repealer Clause.

SECTION 8. Provides for publication of this Ordinance by Summary.

SECTION 9. Establishes an effective date of February 11, 2015.

The full text of this Ordinance is available at the City Clerk's Office, Sun Valley City Hall, 81 Elkhorn Road, Sun Valley, Idaho 83353 and will be provided to any citizen upon personal request during normal office hours.

CITY OF SUN VALLEY, IDAHO

Dewayne Briscoe, Mayor
City of Sun Valley

ATTEST:

Alissa Weber, City Clerk
City of Sun Valley

STATEMENT OF LEGAL ADVISOR

I, the undersigned attorney at law, duly licensed in the State of Idaho and serving as City Attorney to the City of Sun Valley, Idaho, hereby certify that I have read the attached Summary of Ordinance No. 474 of the City of Sun Valley and that the same is true and complete and provides adequate notice to the public of the contents of said Ordinance.

Dated this ____ day of _____, 2015.

Adam King, City Attorney
City of Sun Valley

Publish: Idaho Mountain Express

Date: February 11, 2015